CITY OF LOS ANGELES

BOARD OF **BUILDING AND SAFETY COMMISSIONERS**

> **HELENA JUBANY** PRESIDENT

VAN AMBATIELOS VICE-PRESIDENT

E. FELICIA BRANNON VICTOR H. CUEVAS SEPAND SAMZADEH

CALIFORNIA

ANTONIO R. VILLARAIGOSA MAYOR

DEPARTMENT OF **BUILDING AND SAFETY**

201 NORTH FIGUEROA STREET LOS ANGELES, CA 90012

ROBERT R. "BUD" OVROM GENERAL MANAGER

RAYMOND S. CHAN, C.E., S.E. **EXECUTIVE OFFICER**

MacLean Dixie, LLC 3098 Pelham Parkway Pelham, AL 35124

Attn: Wei-Chung Lin, P.E.

(205) 685-5413

RESEARCH REPORT: RR 25629

(CSI #31 63 00)

BASED UPON ICC EVALUATION SERVICE REPORT NO. ESR-3032

REEVALUATION DUE

DATE: March 1, 2015 Issued Date: April 1, 2013 **2008 LABC** Code:

GENERAL APPROVAL – Reevaluation – Helical Foundation System.

DETAILS

The above assemblies and/or products are approved when in compliance with the description, use, identification and findings of Evaluation Report No. ESR-3032, dated August 1, 2012, of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The parts of Evaluation Report No. ESR-3032 marked by an asterisk are modified or deleted by the Los Angeles City Building Department from this approval.

The approval is subject to the following conditions:

- 1. The approval is for the material of Helical Foundation System only.
- 2. The application is limited to the remedial measures of existing foundation. The foundation system shall not be used for new projects.
- 3. For each job using Helical Foundation System, a soil investigation report shall be submitted to the Grading Section for approval, and plans with complete structural calculations shall be submitted to Structural Plan Check Section for approval and issuance of permits. The structural calculation of the system shall be performed by an architect or engineer registered in the State of California and shall be in accordance with the 2008 Los Angeles City Building Code.

MacLean Dixie, LLC

RE: Helical Foundation System.

4. Installation of Helical Foundation System shall comply with manufacturer's procedures and be under continuous inspection by a Los Angeles City registered deputy inspector.

5. All welded products shall be fabricated by Los Angeles City Department of Building and Safety licensed fabricator.

DISCUSSION

The report is in compliance with the 2008 Los Angeles City Building Code.

The approval was based on tests.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, <u>complete with any attachments indicated</u>, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

ALLEN PEERY, Chief Engineering Research Section 201 N. Figueroa St, Room 880 Los Angeles, CA 90012 Phone - 213-202-9812 Fax - 213-202-9942

RJG RR25629/Word.2010 R04/01/13 2G/1810.3

Attachment: ICC ES Report No.ESR- 3032 (11 Pages)