

ICC-ES Evaluation Report**ESR-1854 FBC Supplement**

Issued February 2015

*This report is subject to renewal February 2017***www.icc-es.org | (800) 423-6587 | (562) 699-0543***A Subsidiary of the International Code Council®***DIVISION: 31 00 00—EARTHWORK
Section: 31 63 00—Bored Piles****REPORT HOLDER:****GREGORY ENTERPRISES, INC.
13655 COUNTY ROAD 1570
ADA, OKLAHOMA 74820
(580) 332-9980
www.ramjack.com
steve@ramjack.com****EVALUATION SUBJECT:****RAM JACK® HELICAL FOUNDATION & DRIVEN FOUNDATION SYSTEMS****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that Ram Jack® Helical Foundation & Driven Foundation Systems, recognized in ICC-ES master evaluation report ESR-1854, have also been evaluated for compliance with the code noted below.

Applicable code edition:

2010 *Florida Building Code—Building*

2.0 CONCLUSIONS

The Ram Jack® Foundation Systems, described in Sections 2.0 through 7.0 of the master evaluation report ESR-1854, comply with the 2010 *Florida Building Code—Building*, provided the design and installation are in accordance with the *International Building Code®* provisions noted in the master report and the following conditions apply:

- Design wind loads must be based on Section 1609 of the 2010 *Florida Building Code—Building*.
- Load combinations must be in accordance with Section 1605.2 or Section 1605.3 of the 2010 *Florida Building Code—Building*, as applicable.

Use of Ram Jack® Foundation Systems for compliance with the High-Velocity Hurricane Zone provisions of the 2010 *Florida Building Code®* has not been evaluated, and is outside the scope of this supplemental report.

For products falling under Florida Rule 9N-3, verification that the report holder's quality assurance program is audited by a quality assurance entity approved by the Florida Building Commission for the type of inspections being conducted is the responsibility of an approved validation entity (or the code official when the report holder does not possess an approval by the Commission).

This supplement expires concurrently with the master report reissued February 2015.